



- A SIRENE, FIRE ALARM
- T THERMAL DETECTOR WITH GROUP NO. MOUNTED ON A SUPPORT. DETECTOR-LEVEL +1500MM OVER SOIL/FLOOR-LEVEL
- G GAS DETECTOR MOUNTED ON A SUPPORT. DETECTOR-LEVEL +1500MM OVER SOIL/FLOOR-LEVEL
- S+J SOLENOID VALVE FOR L.P.G.
- E⊙ EMERGENCY STOP SWITCH WITH 2 SETS OF BREAKING CONTACTS MOUNTED ON A SUPPORT
- O JUNCTION BOX (EEX) *3/1. 1998. Sigurbj. Halld. yf.arker og skingla sáttm. eingangs með ísl. skingra-kerfi.*
- BUNCH OF CABLES TO MAIN DISTRB. PANEL (■)
- BUNCH OF CABLES TO GAS/FIRE ALARM PANEL (∞)

ALL CABLES IN THE GROUND AT LEVEL -800MM

FOR CABLES DIMENSIONS SEE DRWG NO 261B815.4 AND 261B843.4

Brunamálastofnun ríkisins  
SAMPYKKT  
29 JUN 1994  
Sbr. bréf 29/6/1994  
Theodor Árnason  
*Theodor Árnason*

(ABOUT 350M FROM TANK YARD)

Mk.	Rettelise	Dato	Tegn.	Konf.
Kosan Crisplant a/s		Málforhold	Tegn.	KPR
		1:500	Konf.	BRL
		1:200	Goðk.	931021
Erstötning for:		Erstötting af:		
SAFETY INSTALLATIONS IN FIELD SKELJUNGUR hf. STRAUMSVÍK ICELAND		Nr. 261B809.1 Rev. 0		