

Hús C						Hús D						Hús E						Hús F						Hús G						
Tengikista		Slauða		Gólfhitakerfi		Tengikista		Slauða		Gólfhitakerfi		Tengikista		Slauða		Gólfhitakerfi		Tengikista		Slauða		Gólfhitakerfi		Tengikista		Slauða		Gólfhitakerfi		
nr.	nr.	m	l/klst	nr.	nr.	m	l/klst	nr.	nr.	m	l/klst	nr.	nr.	m	l/klst	nr.	nr.	m	l/klst	nr.	nr.	m	l/klst	nr.	nr.	m	l/klst	nr.		
G-C1	C01	120	103,2	G3.SK.01	G-D1	D01	107	92,0	G4.SK.01	G-E1	E01	86	74,0	G5.SK.05	G-F1	F18	96	82,6	G4.SK.04	G-G3	G14	76	130,7	G7.SK.05						
	C02	113	97,2	G3.SK.01		D02	114	98,0	G4.SK.01		E02	118	101,5	G5.SK.01		D19	97	83,4	G4.SK.04		G15	122	209,8	G7.SK.05						
	C03	124	106,6	G3.SK.01		D03	120	103,2	G4.SK.01		E03	117	100,6	G5.SK.01		D20	103	88,6	G4.SK.05		G16	120	206,4	G7.SK.05						
	C04	128	110,1	G3.SK.02		D04	101	86,9	G4.SK.01		E04	118	101,5	G5.SK.02		F01	109	93,7	G6.SK.01		G17	117	201,2	G7.SK.05						
	C05	58	49,9	G3.SK.03		D05	105	90,3	G4.SK.01		F02	90	77,4	G6.SK.01		F02	90	77,4	G6.SK.01		G18	115	197,8	G7.SK.05						
	C06	69	59,3	G3.SK.04		D06	110	94,6	G4.SK.01		E06	93	80,0	G5.SK.03		F03	121	104,1	G6.SK.02		G19	112	192,6	G7.SK.05						
	C07	102	87,7	G3.SK.04		D07	115	98,9	G4.SK.01		E07	93	80,0	G5.SK.03		F04	126	108,4	G6.SK.04		G20	111	190,9	G7.SK.05						
	C08	108	92,9	G3.SK.05		D08	117	100,6	G4.SK.01		E08	96	82,6	G5.SK.04		F05	103	88,6	G6.SK.03		G21	110	189,2	G7.SK.05						
	C09	113	97,2	G3.SK.06		D09	108	92,9	G4.SK.01		E09	103	88,6	G5.SK.04		G-F2	F06	91	78,3	G6.SK.05		G22	109	187,5	G7.SK.05					
G-C2	C10	114	98,0	G3.SK.07	G-D2	D10	122	104,9	G4.SK.02		E10	119	102,3	G5.SK.04		F07	111	95,5	G6.SK.04		G23	108	185,8	G7.SK.05						
	C11	120	103,2	G3.SK.08		D11	131	112,7	G4.SK.02	E11 OG E12 ERU Í KISTU G-G2						F08	123	105,8	G6.SK.04	G24 OG G25 ERU Í KISTU G-G2										
	G24	109	187,5	G7.SK.05		D12	109	93,7	G4.SK.02		G-E2	E14	98	84,3	G5.SK.08	F09	118	101,5	G6.SK.06	G26 OG G27 ERU Í KISTU G-G4										
	G25	114	196,1	G7.SK.05		D13	108	92,9	G4.SK.02		E15	93	80,0	G5.SK.08	F10	108	92,9	G6.SK.06												
G-C3	C12	119	102,3	G3.SK.09		D14	117	100,6	G4.SK.02		E16	108	92,9	G5.SK.08	F11	67	57,6	G6.SK.06	G-G4											
	C13	113	97,2	G3.SK.10		D15	107	92,0	G4.SK.02		E17	117	100,6	G5.SK.09	F12	111	95,5	G6.SK.06	E22 ER Í KISTU G-G4											
	C14	79	67,9	G3.SK.11		D16	115	98,9	G4.SK.03		E18	119	102,3	G5.SK.04	F13	126	108,4	G6.SK.07												
	C15	91	78,3	G3.SK.12		D17	108	92,9	G4.SK.03		E19	122	104,9	G5.SK.04	F14	67	57,6	G6.SK.08												
	C16	99	85,1	G3.SK.13	D18, D19 OG D20 ERU Í KISTU G-F1						E20 OG E21 ERU Í KISTU G-G4						G30	107	184,0	G7.SK.06										
	C17	102	87,7	G3.SK.14							E22 ER Í KISTU G-G4						G31	100	172,0	G7.SK.06										
G-C4	C18	106	91,2	G3.SK.15													G32	100	172,0	G7.SK.06										
	C19	113	97,2	G3.SK.16													G33	86	147,9	G7.SK.06										
	C20	111	95,5	G3.SK.17													E11	109	93,7	G7.SK.06										
	G26	89	153,1	G7.SK.05													E12	112	96,3	G5.SK.06										
	G27	125	215,0	G7.SK.05													G-G5	G34	61	104,9	G7.SK.07									
Samtals:	24	2539	2559,4		Samtals:	17	1914	1646,1		Samtals:	23	2451	2107,9		Samtals:	17	1767	1519,6		Samtals:	26	2693	4226,9							

ALLAR SLAUFUR ERU 20 mm NEMA ANNAD
SÉ TEKID FRAM.

OFNASKRÁ 2. HÆÐ									
OFN NR.	AFKÖST W	GERÐ	L mm	H mm	TENGING	OFNLOKAR	VATNSM. l/h	Kv m³/h	STILLI-TALA
Hús C									
250	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
251	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
252	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
253	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
255	990	VK+C	1600	210	A-D	RA2920	25,8	0,12	5,5
256	990	VK+C	1600	210	A-D	RA2920	25,8	0,12	5,5
258	990	VK+C	1600	210	A-D	RA2920	25,8	0,12	5,5
259	990	VK+C	1800	210	A-D	RA2920	25,8	0,12	5,5
260	990	VK+C	1800	210	A-D	RA2920	25,8	0,12	5,5
261	1.015	22	300	1600	E-F	RA2920	26,5	0,12	5,5
262	990	VK+C	1800	210	A-D	RA2920	25,8	0,12	5,5
263	990	VK+C	1800	210	A-D	RA2920	25,8	0,12	5,5
264	990	VK+C	1800	210	B-C	RA2920	25,8	0,12	5,5
265	990	VK+C	1800	210	B-C	RA2920	25,8	0,12	5,5
266	1.015	22	300	1600	E-F	RA2920	26,5	0,12	5,5
267	194	11	600	300	A-B	RA2920	5,1	0,02	1,0
268	194	11	600	300	C-D	RA2920	5,1	0,02	1,0
269	194	11	600	300	A-B	RA2920	5,1	0,02	1,0
Hús E									
271	580	11	1400	400	A-D	RA2920	15,1	0,07	3,0
272	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
273	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
275	1.015	22	300	1600	E-F	RA2920	26,5	0,12	5,5
276	990	VK+C	1600	210	B-C	RA2920	25,8	0,12	5,5
277	990	VK+C	1600	210	B-C	RA2920	25,8	0,12	5,5
278	990	VK+C	1600	210	B-C	RA2920	25,8	0,12	5,5
279	990	VK+C	1600	210	B-C	RA2920	25,8	0,12	5,5
280	1.015	22	300	1600	E-F	RA2920	26,5	0,12	5,5
282	1.115	VK+C	1800	210	B-C	RA2920	29,1	0,13	6,0
283	1.115	VK+C	1800	210	B-C	RA2920	29,1	0,13	6,0
284	194	11	600	300	A-B	RA2920	5,1	0,02	1,0
285	194	11	600	300	C-D	RA2920	5,1	0,02	1,0
286	194	11	600	300	C-D	RA2920	5,1	0,02	1,0
287	634	22	1000	300	C-D	RA2920	16,5	0,07	3,5
288	963	22	1200	400	A-D	RA2920	25,1	0,11	5,0
289	990	VK+C	1600	210	B-C	RA2920	25,8	0,12	5,5
290	990	VK+C	1600	210	B-C	RA2920	25,8	0,12	5,5
291	990	VK+C	1600	210	B-C	RA2920	25,8	0,12	5,5
292	194	11	600	300	C-D	RA2920	5,1	0,02	1,0
Hús D									
290-A	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
290-B	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
291	194	11	600	300	A-B	RA2920	5,1	0,02	1,0
292	194	11	600	300	C-D	RA2920	5,1	0,02	1,0
293-A	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
293-B	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
293-C	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
293-D	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
294-A	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
294-B	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
295-A	745	11	1800	400	A-D	RA2920	19,4	0,09	4,0
295-B	745	11	1800	400	A-D	RA2920	19,4	0,09	4,0
296	880	22	1400	300	A-D	RA2920	22,9	0,10	5,0
297	2.450	22	2200	600	A-D	RA2920	63,8	0,29	9,5
Samtals:	46.483						1211,4		

OFNASKRÁ 3. HÆÐ									
OFN NR.	AFKÖST W	GERÐ	L mm	H mm	TENGING	OFNLOKAR	VATNSM. l/h	Kv m³/h	STILLI-TALA
Hús C									
350	1.240	VK+C	2000	210	A-D	RA2920	32,3	0,14	6,5
351	1.240	VK+C	2000	210	A-D	RA2920	32,3	0,14	6,5
352	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
353	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	6,0
354	1.142	22	300	1800	E-F	RA2920	29,8	0,13	6,0
355	1.240	VK+C	2000	210	A-D	RA2920	32,3	0,14	6,5
356	990	VK+C	1600	210	A-D	RA2920	25,8	0,12	5,5
357	990	VK+C	1600	210	A-D	RA2920	25,8	0,12	5,5
358	1.115	VK+C	1800	210	A-D	RA2920	29,1	0,13	