

DETAIL-C

FIXING SCREW (RS) -CS-5.5×25/45 SS-5.5×28/50

250 250

DETAIL-B

STITCH SCREWS SHEETING DETAILS (FOR TYPE-S PANEL & ROOF) (SHE-058)

TYPE-'S' PANEL-

USE PANEL MODULE VALUE FOR STITCHING TRIMS/FLASHINGS TO WALL PANELS.

PANEL WIDTH

TYPE-'S' PANEL MODULE

START OF SHEETING

STEP-

EXTEND THE INSULATION BEYOND EAVE STRUT FOR 200-250 mm

ROOF PURLI

STEP-III

FOLD FACING MATERIAL BACK OVER THE TOP OF INSULATION

> SCREW (RS) 150 150 06-0200 SS-5.5×25/45 SS-5.5×28/50

> > SECTION (E)

FIXING SCREW (RS) CS-5.5×25/45 SS-5.5×28/50

-EAVE STRUT

JOP OF RAFTER

REMOVE THE

ROOF PURLIN

STEP-II

WALL/ROOF INSULATION DETAIL AT EAVE STRUT

IMPORTANT NOTES

1 - Roof Panels Type = TYPE-S Thickness = 0.7 (STEEL) Color = FROST WHITE

- 2 Panels are to be field cut to suit openings
- 3 Trims are provided in Zamil Steel standard lengths. Trims quantities are provided to cover the whole length of the trim using 50 mm end laps. Refer to detail TRE-010 at the roof sheeting plan. If lap length specified (50mm) is exceeded during erection then shortage in length may result. If the lap length is reduced then leakage and appearance problems may result.

Always cut any excess trim length at the end of trim line.

- 4 Downspout can be relocated in the site if it is required to avoid the wall accessories.
- 5 Bead mastic must be placed carefully over the panel profile to avoid stretching.


⁶ - SITE STORAGE INSTRUCTIONS

All products are dispatched from our factory in good condition. To maintain this condition, we recommend that the bundles of sheets, purlins or channels are stored 150mm clear of the ground, with a slope of 1:25, to allow for water drainage. Cover the stack with a waterproof cover, leaving the ends open to allow for air circulation.

Upon receipt, it is recommended that bundles of panels be checked. If any water is entrapped between sheets, the sheets should be carefully dried, and then re-stacked allowing for air circulation.

It is recommended that panels be installed as soon as possible after delivery. Extended site storage is not recommended.

Zamil Steel accepts no responsibility for staining of Galvanized, Zincalume or Aluminium products, or deterioration of Painted products due to incorrect site storage.



Byggingafulltrúinn í Hafnarfirði F.h. Hrólfur S. Gunnlaugsson

5-1-15 3-17 6sl F.h. 115 hf. Hjörtur Hansson 11 150946-4929

0	08.10.07	ISSUED FOR APPROVAL	SAK	REM	RM
1	27.11.2007	RE-ISSUED FOR APPROVAL	HKS	REN	RM
2	18.03.2008	RE-ISSUED FOR APPROVAL	HKS	REN	ТМ
3	07.06.2008	ISSUED FOR CONSTRUCTION	ASU	AVP	ТМ



CS-5.5×25 (01-0471)

CS-5.5x45 (01-0472)

CS-5.5×55 (01-0473)

CS-4.8×16 (01-0470)

CS-5.5x25 (01-0481)

CS-5.5×32 (01-0486) FIXING SCREWS

STITCH SCREWS

FIXING SCREWS

(SHE-093)

ROOF SCREW (RS)

ENGINEERING DEPARTMENT

			1 1 1
ZS JOB NO.	: V7-D568	BUILDING NO.: O	1
PROJECT NAME	: SIBERIA HOUSI	E	
CUSTOMER	: HEDINN		
JOBSITE LOCATION	: HAFNAFIRDI, I	CELAND	
DRAWING TITLE	:		DRAWING NO
R	OOF SHEETING F	PLAN	E03