



TENGIMYND HITAVEITU

OFNASKRÁ $\Delta T = 40^\circ C$

OFNAR NR.	HITATAP KCAL/T.	MESTA LENGD	MESTA HÆÐ	TENGI	OFN -
001	320	150	80	C D	
002	1400	130	80	A B	
003	630	150	80	C D	
004	750	150	80	C D	
005	1200	150	80	A B	
006	470	150	80	C D	
100	1700	190	70	B D	
200	1700	190	70	B D	
300	1700	190	70	B D	
101 201 301 111 211 311	400	100	80	C D A B	
401 411	450	100	80	C D A B	
102 202 302 112 212 312	610	125	80	A B A B	
402 412	730	125	80	A B A B	
103 203 303 113 213 313	2370	210	55	B D B D	
104 204 304 114 214 314		110	55	C D A B	
403 413	2625	210	55	B D B D	
404 414		110	55	C D A B	
105 205 305 115 215 315	815	150	65	A B A D	
405 415	940	150	65	A B A D	
106 206 306 116 216 316	455	150	65	A B A B	
406 416	520	150	65	A B A B	
107 207 307 117 217 317	455	150	65	A B A B	
407 417	520	150	65	A B A B	
108 208 308 118 218 318	525	80	50	C D A B	
408 418	590	80	50	C D A B	

BREIÐVANGUR 28 (B & C)	MÆLIKVARÐI ~	VERK 7402	TEIKN NR 19
TENGIMYND HITAVEITU OG OFNASKRÁ	Hannað Teiknað BMS	Yfirfarið Samb. SMB	DAGS SEPT '74.
JÓHANN GUNNAR BERGPÓRSSON VERKFR MVFI STRANDGOTU 11 — HAFNARFIRÐI — SÍMI 53315	BREYTT		