



OFNATAFLA 41-46

NR	Kcal/t	RESTA HÆÐ	RESTA LENGD	PANEL-OFNAR	TENG. ATH.
201	340	700	1200	P 590 - 800	CD
202	750	700	1800	P 590 - 1750	AB
203	350	—	—	P 590 - 880	CD
204	610	700	1550	P 590 - 1520	AB
205	490	700	1580	P 590 - 1200	AB
206	490	700	1580	P 590 - 1200	AB
207	310	600	1000	P 590 - 720	AB
208	695	600	1600	P 2 500 - 1120	AB
209	795	450	1450	P 2 440 - 1440	AB
210	1565	450	3000	P 2 440 - 2800	AB
211	360	280	1700		
212	410	700	1000	P 590 - 960	CD
213	775	—	1150	P 990 - 1120	CD 2.h



SVEINBJÖRN SIGURÐSSON TÆKNIFR.		
MIÐVANGI 116		SÍMI 52256
MTFÍ		
BREIÐVANGUR 50	MKV. 1:50	DAGSETN. 24.6.76
HITALÖGN	BREYTING	DAGS.
STAÐSETNING OFNA		
Á 1.HÆÐ	DRE GIÐ <i>svs</i>	HANNAÐ <i>svs</i>
<i>Sveinbjörn Sigurðsson</i>	7603-9	