

# HITALÖGN: OFNASKRÁ NR. 1.

STAÐUR	OFN NR.	HITAAR. AT = KCAL/H	MESTA LENGD CM	MESTA HÆÐ CM	MESTA DYRKT CM	VALIN OFNGEERD oppofn	VALIN LENGD CM	VALIN HITAAR. AT = KCAL/H	TENGING	OFN-STÚT-AR. MM	HÆÐ F. ENDANL. GÖLFI CM	FJARL. F. ENDANL. VEGG CM	OFN LOKI GERÐ	STILLI-TÉ GERÐ	KVARÐA-STILLING
1. hæð:															
Geymslur	1.1	2745	210	90	12	DK 91	190	2804	CD	10	12		FJVR		
Þvottahús	1.2	585	100	90	12	EK 72	90	654	CD	-	-		FJVR		
Anddyri	1.3	900	180	50	7	EK 52	180	979	AB	-	-		FJVR		
Hjólageyms	1.4	690	100	90	12	DR 72	90	736	AB	-	-		FJVR		
Hjónaherb	1.5	1075	290	80	12	ER 72	270	1324	CB	-	-		FJVR		
Borðstofa	1.6	1025	125	47	15	DK 42	120	972	CD	-	-		FJVR		
Stofa	1.7	820	200	47	15	DK 42	200	1620	CB	-	-		RAVL10/6		
Baðherb.	1.8	240	80	20	7	EK 22	80	205	CD	-	-		FJVR		
Stigag.	1.9	2950	90	30	20	DK 32	90	588	AB	-	-		FJVR		
Borðstofa	1.10	1390	125	47	15	DK 42	120	972	AB	-	-		FJVR		
Stofa	1.11	1390	270	47	15	C 42	270	1781	AD	-	-		RAVL10/6		
Hjónaherb.	1.12	1235	250	80	12	ER 72	250	1226	AD	-	-		FJVR		
Baðherb.	1.13	225	90	20	7	EK 22	80	205	AB	-	-		FJVR		
2. hæð:															
Stofa	2.1	775	65	47	17	TK3-42	60	704	CD	-	-		FJVR		
Stofa	2.2	775	90	47	17	TK3-42	90	1056	AB	-	-		FJVR		
Hjónaherb.	2.3	1225	50 90	47	12	DK 42	50 90	405 729	ABCD AB	-	-		FJVR		
Borðstofa	2.4	2150	285	47	17	DK 42	270	2187	AD	-	-		FJVR		
Baðherb.	2.5	200	90	28	7	EK 42	80	205	AB	-	-		FJVR		
Þvottahús	2.6	800	65	56	25	TK3-52	60	839	AB	-	-		FJVR		
Barnaherb.	2.7	850	120	80	12	EK 72	120	873	AB	-	-		FJVR		
Hjónaherb.	2.8	1035	190	80	12	EK 72	140	1018	AB	-	-		FJVR		
Borðstofa	2.9	1660	125	47	17	DK 42	120	972	CD	-	-		FJVR		
Stofa	2.10	710	200	47	17	DK 42	190	1539	CB	-	-		RAVL10/6		
Baðherb.	2.11	210	70	28	7	EK 22	70	179	CD	-	-		FJVR		
Stigapallur	2.12	2330	220	56	12	DK 52	220	2129	AD	-	-		FJVR		
Borðstofa	2.13	1200	125	47	17	C 42	120	791	AB	-	-		FJVR		
Stofa	2.14	1200	270	47	17	C 42	270	1781	AD	-	-		RAVL10/6		
Hjónaherb.	2.15	1150	150	77	12	DR 72	140	1145	CD	-	-		FJVR		
Baðherb.	2.16	200	90	28	7	EK 22	80	205	AB	-	-		FJVR		

STAÐUR	OFN NR.	HITAAR. AT = KCAL/H	MESTA LENGD CM	MESTA HÆÐ CM	MESTA DYRKT CM	VALIN OFNGEERD	VALIN LENGD CM	VALIN HITAAR. AT = KCAL/H	TENGING	OFN-STÚT-AR. MM	HÆÐ F. ENDANL. GÖLFI CM	FJARL. F. ENDANL. VEGG CM	OFN LOKI GERÐ	STILLI-TÉ GERÐ	KVARÐA-STILLING
3. hæð:															
Stofa	3.1	950	65	47	17	TK3-42	60	704	CD	10	12		FJVR		
Stofa	3.2	950	90	47	17	TK3-42	90	1056	AB	-	-		FJVR		
Hjónaherb.	3.3	1500	60 100	47	17	DK 42 DK 42	60 100	486 810	ABCD AB	-	-		FJVR		
Herb.	3.4A	1650	180	47	17	DK 42	160	1296	CB	-	-		FJVR		
Eldhús	3.4B	650	70	47	17	TK3-42	70	821	AB	-	-		FJVR		
Gangur	3.4C	700	50	47	17	TK3-72	50	896	AB	-	-		FJVR		
Baðherb	3.5	260	100	28	7	EK 22	90	231	AB	-	-		FJVR		
Þvottahús	3.6	910	65	56	25	TK3-52	60	839	AB	-	-		FJVR		
Barnaherb	3.7	1010	80	80	12	C 72	100	1033	AB	-	-		FJVR		
Hjónaherb	3.8	1355	190	80	12	DR 72	160	1309	AB	-	-		FJVR		
Borðstofa	3.9	2050	125	47	17	TK1-42	120	1048	CD	-	-		FJVR		
Stofa	3.10	975	200	47	17	TK2-42	200	2046	CB	-	-		RAVL10/6		
Baðherb	3.11	280	80	28	7	TK22	80	205	CD	-	-		FKVR		
Borðstofa	3.12	1515	125	47	17	DK 42	120	972	AB	-	-		FJVR		
Stofa	3.13	1515	270	47	17	DK 42	260	2106	AD	-	-		RAVL10/6		
Hjónaherb	3.14	1410	150	80	12	C 72	150	1446	CD	-	-		FJVR		
Baðherb.	3.15	260	110	28	7	EK 22	90	232	AB	-	-		FJVR		

SKRIFGAR SJA BL. 4.6.

VÍFILL ODDSSON  
HILMAR KNUDSEN

VERKFRÆÐINGUR FVFI  
VERKFRÆÐINGUR FVFI

TEKNIstofan  
ODINSTORGI

ÖÐINGGÖTU 7 - REYKJAVÍK - Sími 16177

VERKEFNI VALLARBARÐ 1 HAFNARFIRÐI

HEITI HITALÖGN: OFNASKRÁ

T. HK R. HK Y. M.  
DAGS. FEB '84 NR. 42. 4.7

BRETT. 6.11.84 HJ.