


Nr. ofns	Reiknað hitatap		Hámarks-		Tenging ofns framrás/bekrás
	W8tt	Kcal/klst	hrð mm	lengd mm	
301	1705	1475	700	1200	C/D
302	1020	890	700	2000	A/B
303	2340	2020	400	2400	A/B
304	2340	2020	400	2400	C/D
305	820	705	700	1200	C/D
306	1770	1525	700	1700	A/B
307			700	1200	C/D
308			700	1200	C/D
309			400	2400	C/D
310			400	400	A/B
311			700	2000	A/B
312			700	1700	A/B

Skýringar eru á teikn. nr. S-54



**TEIKNIVER,** SELFOSSI  
TEIKNISTOFA, TÆKNIRÁÐJÓNUSTA — Sími (99) 1738

**SAMÚEL S. HREGGVIÐSSON**  
BYGGINGATÆKNIRÁÐINGUR

M.T.F.I.

Sn. 7783/sam

TEIKNAD gs/ssh  
MALT engin

Garðavegur 16 og 18, Hafnarfirði  
Rúmmynd hitalagna rishaðar

Selfossi 29. maí 1983  
Sam. Selgssuif

VERK NR. KE-1.29  
TEIKNING NR. S-56