



OFNASKRÁ

no.	herb.	kcal/t reiknað	valin hæð	valin lengd	sam kv. töflu	teng. stýr.
01	bitgeymsl.	840	P ₂ 74	160		cb
02	andduri	750	P ₂ 59	152		ad
03	eldhús	1550	P ₃ 50	180		ad
04	bordstofa	1700	P ₃ 74	180		ad
05	dagstofa	2200	P ₃ 30	200		ad
06	fjölstykluv.	1000	P ₃ 35	180		cb
07	dagstofa	2000	P ₃ 30	256		ad
08	snarlíngr	150	P ₁ 59	40		cb
09	þvottur	800	334/1075			ad
10	geymsla	650	P ₂ 74	80		ad
11	herbergi	900	P ₂ 59	120		cb
12	snarlíngr	800	214/1060			cb
13	herbergi	1600	P ₃ 59	128		cb
14	herbergi	750	P ₂ 59	128		cb
15	herbergi	850	P ₂ 59	120		cb
16	bitgeymsla	3200	P ₂ 74	248		cb

sjá vinnuteikn. 11, rúmm. hitalagna ofnaval miðar við t=40°C



Glitvangur 1 Matnarrírói
 Þorgrímur Stefánsson t.f.r.
 Hraunbr.12 Kópav. s.43637
 Þorgrímur Stefánsson
 grunnmynd ofnar og ofnaskrá m=1 50
 gert í ágúst 1983