



OFNASKRÁ

Panel - Svissylöfnar Δt 40°C

NR.	HERBERGI	Q_{raud} W	B bykkt cm	H HÆD cm	L LENGD cm	W	A B	TENGLING afmót.	C D	NR.
1	Þvöllur	787	7.8	75	60	784	AD			1
2	Geymsla	334	2.0	60	60	371	CD			2
3	Badherb.	405	7.8	75	48	462	AB			3
4.1	Tömsl. herb.	1273	7.8	60	80	634	AD			4.1
4.2	"		7.8	60	80	634	AB			4.2
5	Anddyri	521	7.8	75	60	578	AB			5
6	Snyrtling	424	7.8	60	60	475	CB			6
7	Herb.	688	7.8	60	100	792	CB			7
8	herb.	795	7.8	60	100	792	CB			8
9.1	Hjona herb.	1410	7.8	60	48	380	CB			9.1
9.2	"		7.8	60	100	1080	CB			9.2
10	Herb.	754	7.8	60	100	792	CB			10
11	Uppgangur	1106	2.0	60	180	1114	CB			11
12.1	Stofa	3317	13.4	21	50	404	Svissyl			12.1
12.2	"		7.8	60	100	1082	AD			12.2
12.3	"		13.4	21	50	808	2.stt. Svissyl			12.3
12.4	"		7.8	60	100	1082	AD			12.4
13	Eldhús	1150	7.8	75	100	1307	AD			13
14	Geymsla	316	2.0	60	60	371	AD			14
	Samt. Hús.	13.137				13.937				
	Þilgeymsla	2.777	7.8	60	100	3.246	CB 3.stt.			

VERK
HÁABARD 16 HAFNARFIRÐI
VATN-HITI RÚMMYND

TEIKN NR 303 AF 8312

HANNAÐ R.G. TEIKNAD

KVARÐI 1:50

DAGS. MAI 1983

BR DAGS BREYTING

PÁLL ZÓPHONIASSON
BYGGINGATÆKNIFRÆÐINGUR
KIRKJUVEGI 23 - 98 2711
900 VESTMANNAEYJUM