


Gr.1	20A	m o	16mm	3	2,5q	Eldavél
Gr.2	10A	m o	16mm	3	1,5q	Tenglar elhúsi
Gr.3	10A	m o	16mm	3	1,5q	Wc, eldhús og stofa
Gr.4	10A	m o	16mm	3	1,5q	Anddyri
Gr.5	10A	m o	16mm	3	1,5q	Hesthús
Gr.6	10A	m o	16mm	3	1,5q	Geymsla
Gr.7	10A	m o	16mm	4	1,5q	Útljós
Gr.1	10A	m o	16mm	3	1,5q	Tenglar eldhúsi 2.hæð
Gr.2	10A	m o	16mm	3	1,5q	Hesthús
Gr.3	10A	m o	16mm	3	1,5q	Anddyri og hlaða
Gr.4	10A	m o	16mm			WC og eldhús 2.hæð
Gr.5	10A	m o	16mm			Auka

Heimtaug OR  
50mm PEH rör  
útfyrir lóðamörk

10q  
Sökkulskaut  
10q  
Pípukerfi

*[Signature]*  
Kt. 110457-2789

 <b>RAF GULL ehf</b> Selvogsbraut 4, 815 Þorlákshöfn, S: 483 3545, Fax: 483 1170, Netfang: rafgull@isl.is	Hannað af kt.101276-3849 <i>RG</i>	Yfirfarið af kt.171153-5739 <i>GE</i>	Skrárheiti Ingi hesthús	Dagsetning 07.06.2005	Mælikvarði 1:50
	<b>Hesthús Töfluteikning</b>		Verkhúti <b>Rafmagnsteikningar</b>		
Heimilisfang Kaplaskleið 22	Sími	1		Blað nr. 3/3	