



OFNALISTI

NR.	Nauðsynleg afköst [W]	Gerð/hæð [mm]	Lengd [mm]	Afköst við $\Delta T=40^{\circ}\text{C}$ [W]	Stöta stöðs. 10mm	Stíllitla ofnloka
033	1080	500	1200		AB	
102	1093	500	900		AB	
103	1093	500	900		AB	
104	1093	500	900		CD	
201	1093	500	900		CD	
202	1093	500	900		CD	
203	1093	500	2000		AD	
204	2430	500	900		AB	
205	810	500	900		AB	

Á ALLA OFNA KOMI FRAMRÁSALOKAR, STILLITÉ, AFTÆMING OG LOFTSKRÚFA

26 APR. 2002

ÚT. DAGS. BREYTING: HANNAÐ SAMD.

ÍRÓTTA- OG KENNSLUMIDSTÖÐ HAUKAHRÁUNI 1, 220 HAFNARFIRDI	HITLAGNIR, VIÐBYGGING RÖMMYND
VSB VERKFRÆÐISTOFA	Áritun lögg. hönnuða: <i>[Signature]</i> Björn Ólafsson, Kt.:180550-4889.
BEJARHRAUNI 20+220 HAFNARFJÖRÐUR Heimasíða: www.vsb.is • Netfang: vsb@vsb.is Sími: 585-8600 Fax: 585-8610 Kt.: 1710796-2899	Hönnuð: EB Teiknað: LA Mál: 1:50 Yfirfarir: Dags: 21.11.01 Nr: 00805-P09

