



OFNALISTI

NR.	VARMAPÖRF KCAL / KLST	OFNSKOT		TENGING	VALDIR OFNAR	HITAGJÖF KCAL / KLST
		HÆÐ	LENGD			
101	1470	70	180	A - D		
102	912	70	140	A - D		
103	530	70	130	A - D		
104	1270	70	110	C - D		
105	2850	25	450	A - D		
106	1560	70	220	A - D		
107	1452	70	180	A - D		
108	450	70	110	C - D		
109	700	70	100	C - D		
110	530	75	60	A - B		
111	200	75	50	C - D		
112	815	50	110	A - D		
113	684	70	110	A - D		
114	1090	70	110	A - D		
115	1925	70	340	A - D		

ATHS.

- TENGINGAR OFNA MIÐAST VIÐ 
- ADRAR SKÝRINGAR ERU Á BLAÐI 2.01
- $\Delta T = 40^\circ\text{C}$

5. febr. 1982



Br. Dags. Breyting varðar.

Verkfræðipjónusta
Guðmundar Óskarssonar
Ráðgefandi verkfræðingar
Skiptolt 15 Reykjavík Símar 15941

HRAUNTINGA 24, HAFNARFIRÐI
GRUNNMYND HITALÖGN

Reykjavík DESEMBER 1981
Akureyri: VKO
Reikn.: GI
Yfir:
Samb:
Kvarðr:
Verk nr.:
Bl. nr: 231