



OFNASKRA					
OFN NR.	AFKÖST KCAL/KLST	HÁMARKS-		STAÐS. STÚTA	VALDIR OFNAR
		HÆÐ	LENGD		
(01)	(200)	cm	cm	C-D	
02	800	60	150	C-B	
03	1240	~14	150	C-D	
04	950	60		A-B	
05	900			C-B	
06	190			A-B	
(07)	1350			C-D	
(08)	550			A-B	
11	1200	55		A-B	
12	2600	55	310	C-B	
13	2240	55	~250	C-B	
14	2240	55	~250	C-B	
15	1200		90	C-D	
16	770			C-D	
17	740	70	150	C-B	
18	270		80	C-D	
19	1750			A-B	
21	2090	55	340	A-B	



SKAL VERA ÚR DREGNUM SVÖRTUM STÁLPIPUM.
 LUR SKAL EINANGKA MEG 20MM G-GERULLAR EÐA
 M. OG SÍVEPJA NEÐ PLASTDÚK.

OFNASTERBIR SKULU MIBASTVIÐ Δt = 40°C.
 SÁLFVIRKUR OFNHITASTILLIR SKAL VERA 'A'
 BAKRENSLISPIPU FRA ÖLLUM OFNUM (P3VR).
 ALLIR OFNSTÚTAR ERU Ø 10 MM (3/8")
 'A' ALLA OFNA SKAL SETJA STILLITE ÖÐRU MEGIN.

Gunnar Ingi Ragnarsson
 BREYTT 11.08.1980

LEKJARHAMMUR 1. HAFNARFIRÐI	VERKNR. 117
HITALÖGN RÚMMYND	M 1:50
GUNNAR INGI RAGNARSSON FVPI LAUFASVEGI 54 REYKJAVIK S 16908	L04