



OFNA SKAL VELJA FYRIR $\Delta T=40^\circ$

OFN NR.	VARMAÐ. KCAL/T	MESTA LENGD	MESTA HÆÐ	TENG. A B C D	OFN LOKI
101	470	1000	750	A-B	BAKR. LOKI
102	550	800	750	A-B	- " -
103	1330	1800	350	A-D	- " -
104	860	800	750	A-B	- " -
105	550	800	750	A-B	- " -
106	550	800	750	A-B	- " -
107	2440	3600	350	C-B	- " -
108		800	350	C-D	- " -
109		800	350	C-D	- " -
110	1200	1800	750	C-D	BAKR. LOKI
111	800	1200	750	A-B	- " -
112	200	500	600	C-D	- " -
113	400	600	750	A-B	- " -
114	630	800	750	A-B	- " -
115	1200	1900	750	A-D	- " -

SKÝRINGAR: SJÁ TEIKN. 2000.



HÚSNÆÐISSTOFNUN RÍKISINS
 LAUGAVEGI 77, REYKJAVÍK
 Sími 28500

VERK NR. **A.05.11.** TEIKN. NR. **3.201**

LYNGBERG 21. HAFNARFIRDÍ.
 HITA-OG VATNSLÖGN.
 GRUNNMYND.

HANNAD	BBS.	STADFERT	
REIKNAD	BBS.	YFIRFARID	
TEIKNAD	KBJ.		
KVARDI	1:50		

Benedictus Sigurðsson
Byggingarfræðingur