


OFNALISTI

OFN NR	MESTA H	L	VAERNAÐER KVAÐ/ST	STARSETN- ING STLITA
1	60	70	1050	AD
2	60	130	1050	AD
3	60	100	950	CB
4	60	50	350	AD
5	60	100	1050	CB
6	60	130	2150	AD
7	60	130	2300	AD
8	60	130	1950	AD
9	60	130	1620	CB
10	60	130	1250	CB
11	60	130	1700	AB
12	40	130	1700	CB
13	40	340	3400	CB
			$\Delta t = 50^\circ\text{C}$	21.770
			t herb. = 20°C (25°C i badh.)	

- 1) 0°C 40°C
- 2) þrygðiprófan
- 3) Styrting kerfis
- 4) þrygðitap mm/vs
- 5) einangrun íbúa



SKÝRINGAR SJA TEIKN.NR. V-9-B

KVARDI TEIKNISTOFA HRINGBRAUT 121 REYKJAVIK SIMI 26340

VERKEFNI NORÐURVANGUR 3-9 HAFNARFIÐI	MAL 1:50	VERK NR. 3-72-27
HITALÖGN GRUNNHAND	DAGS. 9-10-72	ER
REIKN. AD	TEIKN. aa	TEIKN NR. V-9a

Andri Snær Magnason FSTi