



HÚSVEITA TENGIST Á R-FASA

kWH

Heimtaug RR  
1x63A 50mm

63A  
PEN N

63/0,03A

Gr: 1	25A	Π O	25 mm	3	4 mm <sup>2</sup>	Eldavél
Gr: 2	16A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Þvottavél/þurrkari
Gr: 3	16A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Tenglar í eldhúsi
Gr: 4	10A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Eldhús
Gr: 5	10A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Anddyri, Þvotta/þurrkrými, snyrting, stigi
Gr: 6	10A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Stofa
Gr: 7	10A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Herbergi, gangur, bað - 2. hæð
Gr: 8	10A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Herbergi 2. hæð
Gr: 9	10A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Útiljós
		Π O	16 mm	3	1,5 mm <sup>2</sup>	Útiljós - ljósnemi
Gr: 10	16A	Π O	16 mm	3	1,5 mm <sup>2</sup>	Uppþvottavél

6mm<sup>2</sup>  
Grunntenging baðs og sturtubotns

16 mm  
20 mm  
16mm<sup>2</sup>  
Grunntenging vatnspípukerfis

Tenging við sökkulskaut

BREYTING A	BREYTING B	BREYTING C	BREYTING D	VERKHEITI Stuðlaberg 32	DAGS. júlí 88
MKV. ENGINN	CM 0 5 10	TEIKNAD des	YFIRF.	SAMP.	VERKHLUTI Einlínnumynd töflu
				HANNAÐ des	TEIKN.NR. 33-032-2-4
					BREYT.



**RAFTÆKNISTOFAN**  
SUDURLANDSBRÁUÐ 4 • Sími 91-660080