

EYRARTRÖÐ 4, HAFNARFJÖRÐUR
AFKÖST - GÓLFHITALAGNIR STARFSMANNARÝMI
TAFLA YFIR GÓLFGEISLA, FRAMRÁSARHITI 42°C

	SLAUFNA NR.	REIKNUD AFKÖST (W)	MINNSTU AFKÖST (W)	LENGD SLAUFU (M)	ATHUGASEMDIR
SLAUFNA-01 BAD	01	522	876	73	LAGNIR SÉU #20*2.0
SLAUFNA-02 BAD	02	522	816	68	
SLAUFNA-03 BÚNINGSH.	03	706	1,056	88	
SLAUFNA-04 FATAHENG	04	480	516	43	
SLAUFNA-05 SNYRTING	05	900	948	79	
SLAUFNA-06 GANGUR	06	650	852	71	
SLAUFNA-U01 SÝRUH.	U01			137	LAGNIR SÉU #25*2.5
SLAUFNA-U02 TRÖPPUR	U02			67	LAGNIR SÉU #25*2.5
SAMTALS:		3,780	5,064	422	

EYRARTRÖÐ 4, HAFNARFJÖRÐUR
AFKÖST - GÓLFHITALAGNIR 1. HÆÐ
TAFLA YFIR GÓLFGEISLA, FRAMRÁSARHITI 42°C

	SLAUFNA NR.	REIKNUD AFKÖST (W)	MINNSTU AFKÖST (W)	LENGD SLAUFU (M)	ATHUGASEMDIR
SLAUFNA-11 SALUR	11	746	1152	96	LAGNIR SÉU #20*2.0
SLAUFNA-12 SALUR	12	746	1188	99	
SLAUFNA-13 SALUR	13	746	1080	90	
SLAUFNA-14 ELDHÚS	14	1015	1056	88	
SLAUFNA-15 GANGUR	15	853	828	69	
SLAUFNA-U11 SVALIR	U11			137	LAGNIR SÉU #25*2.5
SAMTALS:		4,106	5,304	442	

EYRARTRÖÐ 4, HAFNARFJÖRÐUR
AFKÖST - GÓLFHITALAGNIR 2. HÆÐ
TAFLA YFIR GÓLFGEISLA, FRAMRÁSARHITI 42°C

	SLAUFNA NR.	REIKNUD AFKÖST (W)	MINNSTU AFKÖST (W)	LENGD SLAUFU (M)	ATHUGASEMDIR
SLAUFNA-21 SALUR	21	911	1152	96	LAGNIR SÉU #20*2.0
SLAUFNA-22 SALUR	22	911	1188	99	
SLAUFNA-23 SALUR	23	911	1080	90	
SLAUFNA-24 GANGUR	24	1142	1020	85	
SLAUFNA-25 VS/ GANGUR	25	900	1020	85	
SAMTALS:		4,775	5,460	455	

5/1116 1412339

Samykkt þann
06 OCT 2016
Byggingartillittrúinn í Hafnarfjörð
F.h. Sigurður Steinar Jónsson

SKÝRINGAR:

Í SAMRÆMI VIB SAMÞYKTTA AÐALUPPRÆTTI

Sveinbjörn Jónsson kt. 261254-7949

ENDURSKODUN:	DAGS:	TEKN. YFIRF.
H:		
G:		
F:		
E:		
D:		
C:		
B:		
A:		

VERKKAUPI: GULLMOLAR ehf.
VERKHEITI: EYRARTRÖÐ 4, HAFNARFJ.
EFNI: GÓLFHITALAGNIR

VERKFRÆÐISTOFAN: **möndull**
Sveinbjörn Jónsson, 100% Resögávegur
Súna 2325-7949, hl. 991 544 1139
Símanúmer 070-1211
E-mail: sveinbjorn.jonsson@mendull.is
Byggingaverkefningur

TEMA: 2325-M-101
YFIRSEÐUR: SVBJ
VERK NR: 2325
BLAÐ NR: M101

DAGS. ÚTGAFU: SEPT-2016
KENNTALA ÚTGEFANDA: 261254-7949
STAFB: A1
ENDURSK.

SJÁ ENNFREMUR SKÝRINGAR Á TEIKNINGU P-001

