



LYKILMYND 1:200

HITATAFLA

Dalshraun 6	Nr. Sl/ofs	Útreiknað varmaþörf [W]	Stærð á s.l/ofni H x L (mm)	Valinn ofn Aðköt [W]	Lokar	Athugasemd
Innkeyrsla	101	5,649 W	600C 2200	3,085 W	Fmúrás	
	102		600C 2200	3,085 W	Fmúrás	
Skrifstofa	103	2,073 W	600C 1800	2,524 W	Fmúrás	
Satur-gólflokkun	104	20,008 W	600E 1400	2,701 W	Fmúrás	
	105		600C 3000	4,207 W	Fmúrás	
	106		600C 3000	4,207 W	Fmúrás	
	107		600C 3000	4,207 W	Fmúrás	
	108		600C 3000	4,207 W	Fmúrás	
Kaffistofa	SI1	8,548 W	L-100m	1,800 W	TH	
	SI2		L-90m	1,620 W		
	SI3		L-80m	1,440 W		
	SI4		L-90m	1,620 W		
	SI5		L-80m	1,440 W		
	SI6		L-60m	1,080 W		
Anddyri	109	2,202 W	600C 600	841 W	Bakrás	
	110		600A 2000	1,467 W	Bakrás	
Ræsting	111	507 W	600B 600	616 W	Fmúrás	
Snyrtng	112	352 W	600A 600	440 W	Bakrás	
Snyrtng	113	299 W	600A 600	440 W	Bakrás	
Snyrtng	114	410 W	600A 600	440 W	Bakrás	
Snyrtng	115	323 W	600B 600	616 W	Bakrás	
Snyrtng	116	446 W	600A 600	440 W	Bakrás	
Inntaksrymi		703 W				
Fátalbergíog gangur	117	1,630 W	600B 1600	1,632 W	Fmúrás	
	118		600A 1200	881 W	Fmúrás	
Gangur og geymsla		601 W				Hítakista
Lagnabót	201	1,792 W	600B 1800	1,839 W	Fmúrás	
		Varmahörf alls: 45.801 W		Valið alls: 46.915 W		

VEKTOR
- hönnun og ráðgjöf
Síðunna 3, 108 Pósth. s. 554-6650 / 897-5363

Sigurður Halsteinnsson
Byggingarkonráðgjafi
Kl. 93369-7749
emak.sigur@vektor.is

DALSHRAUN 6, HAFNARFIRÐI

HITALAGNIR
GRUNNMYND OG DEILI

Tekn. nr. 11000000000000000000
Samþykkt: *[Signature]*

Br. Dags. *[Signature]*

Húsnúmer: SH, Ískráð: MA
Dagsetning: 20.02.2017, Vorkr.: 1:50, Mælskaft: L-301, Tekn. nr.: L-301