



Samykkt þann
 01 OCT 2012
 Byggingafráttirinn Hlutfærðir
 Fh. Sigurður Steinar Jónsson

Níels Indriðason
 11144-3949
 NI

- Skýringar Legend:
- ① Cable conduit under slab to cable trench in floor, ø63mm PEH
 - ② Cable conduit in gravel to cable trench in floor, ø63mm PEH
 - ③ Cable conduit from Oil Pit to cable trench in floor ø32mm PEH.

16	Record Drawing	2012.06.11	HS	NI	BS	MS	
Útg. nr.	Rev. no.	Dagsetning	Har/Þn	Yfir/	Notk. heim.	Notk. heim.	ISAL Ref.
		Date	Des/Drw	Chk	Suppl	ISAL Ref.	

This drawing is the property of Rio Tinto Alcan Iceland Ltd. and is handed out for personal use only. It may neither be copied nor made available to others without permission of Rio Tinto Alcan Iceland Ltd. The receiver is liable for any misuse.

HRV HATCH
 ISAL PRODUCTION UPGRADE

Dagsetning / Date: 2008.12.01
 Hannað / Designed: IHS
 Tekn. / Drawn: LDB
 Verktaki / Supplier: HRV
 Tekn.nr./verktaka / Supplier drw.no.: IDP-410-CA-015-079
 Samþykkt / Approved: NI
 Flutti af / Part of:

IPU 410 - SUBSTATION		Flakur nr.:	Blað nr.:	Næsta bl. nr.:
220 kV SWITCHYARD BLD.		Kostn.nr.-Cóno. / Blán.nr.-Egno.	4011	01188
FOUNDATION AND BOTTOM SLAB		Teg. teikningar / Dwg. type:	CONCRETE WORK	AKS
		UB01		
RioTintoAlcan		ISAL Tekn.nr. ISAL / Drw.no. of ISAL / Breyt./Rev.	251235	A
		ISAL Yfirfarð og skráð, dags / ISAL Checked, date		ISAL Samþykkt, dags / ISAL Approval, date