


OFNASKRÁ Δ T 40°C				
OFN NR.	VARMAÞÓRF kcal/klst	MESTA HÆÐ mm	MESTA BR. mm	TENGING A B C D
101	2300	750	2800	CD
102	780	600	1000	AB
103	545	600	1000	AB
104	330	600	800	CD
105	950	600	3000	AB
106	1300	600	2000	AB
107	2300	300	2600	BC
108	670	600	1000	AB
109	680	600	1000	CD
201	1070	600	1600	CD
202	680	600	1800	CD
203	780	600	800	CD
204	1630	500	1400	AD
205	1130	250	1500	CD
206	1530	250	2800	CD
207	850	600	1000	CD
<u>16.675 kcal/klst</u>				

Á OFNA NR. 101, 102, 103, 105, 107, 108 OG 109
SKAL SETJA TÆMINGARLOKA

Almennar skýringar sjá bl. nr.1.



RÚMMYND

STUÐLABERG 28,	HAFNARFIRÐI	VERK NR. 351-III 7
RÚMMYND OFNAR, OFNASKRÁ OG MÆLIGRIND	BL. NR. 8	KVARDI TEIKN. NR.
	1:50	
Hannað SG	Teikn. SG/HÁ	Yfir. <i>SG</i>
	Sambýkt <i>Guðmundur Magnússon</i>	Daga. JÚLÍ 1989

①	06.90	BREYTING Á OFNALÖGNUM - OFNASKRÁ	KMP
Breyting	Daga.		Sign.

VGM Verkfæðistofa
Guðmundar Magnússonar
VERKFRÆÐISRÁÐGJAFAR FKH, HAFNARÞING 7 KÓPAVOGUR, SÍM. 42200