



$\Delta t = 40^\circ \text{C}$.

ATH ! OFNASTÆRDIR SKULU ATHUGAST Á STADNUM ÁÐUR EN OFNAPÖNTUN ER GERD.

OFN. NR.	GERD	LENGD. CM.	HÆÐ. CM.	AFKÖST KCAL/H.	TENGENG. FRAM. BAK.	VALDIR OFNAR. GERD. AFK.
1.1		100	60	600	C D	
1.2		100	60	500	C D	
1.3		100	60	470	A B	
1.4		130	60	1140	A B	
1.5		130	60	1100	A B	
1.6		170	60	1400	A B	
1.7		100	60	250	A B	
2.1		100	60	840	A B	
2.2		80	60	1010	A B	
2.3		250	70	2180	C D	
2.4		130	60	1560	A B	
2.5		130	60	970	A B	
2.6		130	60	880	A B	
2.7		170	30	1200	C D	
2.8		170	30	1200	C D	
2.9		170	60	2000	C D	
2.10		130	60	1510	C D	
2.11		100	60	660	A B	
2.12		100	60	700	A B	
2.13		90	60	830	C D	

LL. Merkir Ø 100 mm. loftrás út úr vegg lokað að utan með veðurríst.

GRUNNMYND NEDRI HÆÐ — MKV 1:50

Samþykkt þann
04 OKT. 2000
Byggingafulltrúinn í Hafnarfirði
Fh. Sigurbjartur Halldórsson

SUDURHOLT 9 HAFNARFIRÐI.
HITALÖGN OG VATNSLÖGN GRUNNMYND NEDRI HÆÐ.
JÚLÍ. 1999. MKV. 1:50.

Jóhannes Pétursson 010448-3959 S - 567-5107
Sigurður Sigurðsson 021146-2349 S - 566-6613

BR 1 APR. 2000