



Ofnatafla Ofnar eru reiknaðir fyrir $\Delta t = 40$

Herb Nr.	Hitalap kcal/h	Swenskir P-ofnar Lengd x Hæð - þykkt
101	1200	1200 x 590 - P3
102	1210	1600 x 590 - P2
103	260	640 x 590 - P
104	760	1040 x 590 - P2
105	1360	1200 x 590 - P1
		1200 x 590 - P2
106	850	1240 x 740 - P
107	1530	1520 x 590 - P3
108	2010	2720 x 440 - P3
		3520 x 440 - P3
109	1000	1360 x 440 - P3
110	770	1080 x 590 - P2
111	1000	1400 x 590 - P2
112	620	640 x 740 - P
001	1150	1360 x 740 - P2
002	2 x 1360	2 stk. 1560 x 740 - P2
003	2 x 2100	2 stk. 2400 x 740 - P2

Samt. 23.240 kcal/h

Ofnar eru samkvæmt ofnatöflu
 Á alla ofna komi Danfoss ofnventlar FJVR
 nema á ofn nr. 108A komi typra RAV 10



þrúðvangur 15 Hafnarfirði		Gunnar Erlendsson Tæknifræðingur Sími 4-21 75	
Hitalögn		Mælikv. 1:50	Teikn. Okt. 1971