



TENGIMYND HITAVEITU

OFNASKRÁ $\Delta T = 40^\circ C$

NR.	HITATAP KCAL/T.	MESTA LENGD	MESTA HÆÐ	TENGI	OFN - PANEL
1	1780			CB	P2/740/2080
2	510			AB	P1/740/960
3	550			AB	P1/740/1040
4	1390			AB	P3/990/800
5	520			CD	P2/500/880
6	1090			CD	P2/590/1520
7	900			CB	P2/300/2240
8	2160			CB	P3/300/1200
9				AD	P3/300/2800
10	1300			AD	P3/440/1760
11	770			CB	P2/500/1280
12	1070			AD	P2/500/1680
13	530			AB	P1/500/1440
14	620			CD	P2/500/1040
15	590			AB	P2/500/1040
16	720			AB	P2/740/640
17	760			EF	P3/990/480
18	220			AB	P1/740/400

VESTURVANGUR 68-39	MÆLIKVÆÐI ?	VERK 7413	TEIKN NR 14
TENGIMYND HITAVEITU	Hannað: Teiknað: <i>DM</i>	Yfirráð: Samb:	DAGS AGÚST 74
JOHANN GUNNAR BERGPÓRSSON VERKFR MVFI STRANDGÖTU 11 — HAFNARFIRÐI — Sími 53315	BREYTT		