Format A1 (841x594 mm) is 20 mm outside of this frame

GRUNNMYND KJALLARA - HITALAGNIR

1:50



OFNASKRÁ

Tegund, td.		Framrás/bakrás=80°/40°C		dt=40°C		dp = 0,10bar		
Ofn nr.	Stærð ofnloka	Gerð/hæð ofna [mm]	Lengd ofna [mm]	Afköst W	Stúta-staðsetn.	Stillitala Ofnloka Danf.-RA-N	Stillitala Ofnloka TA-v.vinkil	Stillitala Ofnloka TA-beinn
001	DN10	11-770	2000	1574	CB	3	5	5
002	DN10	22-770	1000	1400	CB	3	4	4
003	DN10	22-770	1000	1400	AD	3	4	4
004	DN10	11-770	2000	1574	CB	3	5	5
005	DN10	11-770	2000	1574	CB	3	5	5
006	DN10	11-770	2000	1574	AD	3	5	5

Samþykkt þann
22 OKT 2003
Byggingafulltrúinn í Hafnarfirði
Fh. Sigurbjartur Halldórsson

Kt. 170347-7499

Skýringar:
Explanations:

VGK Verkfræðistofa

Breyt. Rev.	Breyting Revision	Dags. Date	Samþ. Approved	Notk. heimil. Released

Tilv.teikningar nr. ISAL
Ref.drawing no. of ISAL

Samsetn.teikningar nr. ISAL
Assembly drawing no. of ISAL

This drawing is the property of the Alcan Iceland Ltd. and handed out for personal use only. It may neither be copied nor made available to others without permission of the Alcan Iceland Ltd. The receiver is liable for any misuse.

Fjöldi stykkja / Number of pieces: IV III II I

Hlutur / Object | Atriði / Item | Efni / Material | ea.:stk / Weight | total: í heild / (kg) Þyngd | Athugasemdir / Remarks

SKRIFSTOFUHÚS ALCAN
GRUNNMYND KJALLARA
HITALAGNIR

Stærð / Format: A1 | Mkv. / Scale: 1:50
Kostn.nr.-bún.nr. / CCno.-Eq.no.: 4110 01199
AKS no.: UM10
Verktaki / Supplier: VGK CONSULTING ENGINEERS LTD.
Teikn.nr. verktaka / Drw.no. of suppl.: 9K-70 | Breyt./Rev.
Teiknað / Drawn: ÓS | Yfirfarið / Checked
Samþykkt / Approved
ALCAN PRIMARY METAL EUROPE
ISAL
Alcan Iceland Ltd
Straumsvík
IS-222 Hafnarfjordur
Drw.no. of ISAL / Teikn.nr. ISAL: 168809 | Breyt./Rev.
Teiknað / Drawn | Yfirfarið og skráð / Checked and filed | Notkun heimiluð / Released