



OFNATAFLA

At = 40 C° Ofnategl = 10mm

Cfn. Nr.	Ofn. Tegund	Tenging	W. Orkuþór	Ath.
801	P21 - 600 x 1000	CD	1050	
802	P11 - 600 x 1000	AB	620	
803	P21 - 600 x 600	AB	560	
804	P11 - 600 x 1480	EF	1050	andarelstur
805	P21 - 600 x 800	CD	560	
806	P11 - 600 x 1000	CD	620	
807	P21 - 600 x 1000	AB	1050	
808	P21 - 400 x 800	AB	340	
809	P21 - 600 x 1000	CD	892	
810	P21 - 600 x 2000	BC	2000	
811	P11 - 600 x 2000	AD	1360	
812	P11 - 600 x 2000	BC	1360	
813	P21 - 600 x 2000	AD	2000	
814	P21 - 600 x 1000	AB	890	
815	P21 - 400 x 500	AB	340	
GOLFHT	Ø20 PEX - EPA - SAMB.			SJA TEIKN. NR. 203

Allir valdir ofnar PANEL-ofnar nema annad sé nefnt.

26 OCT 1992



Breytingar		EYRARHOLT 6, HAFNARFIRÐI	
Nr.	Dagur	Nafn	
1	10.10.92	Asmundur Asmundsson	VERKSTADGEGGUR HAFNABERG KÓP. LÍNA 44373
2	11.10.92		
HITA - OG HREINLETTISLAGNIR		GRUNNMYND 8. HÆÐAR	
		SJA TEIKN. NR. 203	
		Dagur JUNÍ 92	
		213	