


TAFLA T2
1N 400/230V 50Hz
Íbúð 65

TAFLA T1
1N 380/220V 50Hz
Íbúð 65

- GR.1 10A 3 1,5² Þvottahús og bað
- GR.2 10A 3 1,5² Hjónaherbergi og fataskápur
- GR.3 10A 3 1,5² Anddyri og litla bað
- GR.4 10A 3 1,5² Gangur og fjölskylduhol
- GR.5 10A 3 1,5² 2xherbergi
- GR.6 10A 3 1,5² Stofa
- GR.7 10A 3 1,5² Eldhús og borðstofa
- GR.8 16A 3 1,5² Örbylgjuofn
- GR.9 16A 3 1,5² Ofn
- GR.10 16A 3 1,5² Uppþvottavél
- GR.11 25A 3 4² Eldavél
- GR.12 16A 3 1,5² Þvottavél
- GR.13 16A 3 1,5² Þurrkari
- GR.14 10A 3 1,5² Ísskápur
- GR.15 16A 3 1,5² Nuddbað

- GR.1 10A 3 1,5mm² Bílskúr
- GR.2 16A 3 1,5mm² Sértingill í bílskúr
- GR.3 10A 3 1,5mm² Sértingill bílskúr
- GR.4 10A 3 1,5mm² Smáspennuskápur
- GR.5 10A 3 1,5mm² Útiljós og tenglar
- GR.6 32A 5 10mm² Tafla T2

Mótt 26/7 2007
SA

Verkheiti Drekavellir 65 - Hafnarfirði		
Verkhúti/Verknúmer		
Einlínunmyndir		
Blað.n. 4/4	Dags. 15.mars.2007	Kvarði 1:50
Yfirfarir <i>Sigurjón Harðarson</i>		
Hönnuður <i>Sigurjón Harðarson</i>		
Samræmingar hönnuður		
Breyting		
 Miðvangi 125 220 Hafnarfirði kt. 700402-5090 Sími 565 1846, fax 565 0940 gsm 898 0970 http://www.munus.is, e-mail munus@munus.is Hönnuður Sigurjón Harðarson, kt. 060361-2749		