



Samþykkt þann

09 OKT. 2006

Byggingafulltrúinn í Hafnarfirði  
Eh. Sigurbjartur Halldórsson

OFNALISTI						OFNLOKAR	
Ofn.nr	Gerð VÖRYL	Hæð cm	Lengd cm	Tenging	Afköst 40c (Watt)	Gerð Danfoss	Stíllitala
201	C(22)	40	120	AB/CD	1219	RA-N/RA2010	2.5
202	C(22)	40	70	AB/CD	711	RA-N/RA2010	1.5
203	C(22)	40	70	AB/CD	711	RA-N/RA2010	1.5
204	C(22)	40	120	AB/CD	1219	RA-N/RA2010	2.5
205	Handklæðaofn 60*120			EF	580	RA-N/RA2010	1.0

*Handwritten signature*

TEKNIÞJÓNUSTAN SF  
Lágmúla 5-108 Reykjavík  
Sími 581 3844 fax 581 4740  
e-mail glafur@tth.is  
*Handwritten signature*  
110350-4659

SMYRLAURAUN 5  
HAFNARFIRÐI  
GRUNNMYND 2HÆÐ  
HITA-OG HREINLÆTISLAGNIR

Hannað: ÓÁþ Dags: 9-006  
Teikn: ÓÁþ Yfirfarið:  
Kvarði: 1:50  
Nr.: L0608  
Blað: 4  
Af: 5

Br. Dags. Breyting