

OFNASKRÁ 1.HÆÐ

Hitaveita Framrás 75°C  
Bakrás 35°C  
Innihiti 20°C  
dt=35°C

Herbergi	Ofn nr	Afköst W	Hæð	Lengd	Valdir ofnar	Ofnlokar
Skrifstofa	101	850	400	2600		
"	102	650	400	1800		
"	103	650	400	1800		
"	104	1000	400	2500		
"	105	650	400	2000		
"	106	650	400	2000		
"	107	650	400	1800		
"	108	650	400	1800		
"	109	650	400	1800		
Stigahús	110	1480	700	1200		
Anddyri	111	1000	600	1400		
Skrifstofa	112	650	400	1800		
"	113	650	400	1800		
"	114	650	400	1800		
"	115	650	400	1800		
"	116	650	400	1800		
"	117	650	400	1800		
"	118	650	400	1800		
"	119	650	400	1800		
"	120	700	400	1800		
"	121	700	400	1800		
Anddyri	122	1300	600	2400		
Búningsherbergi	123	750	400	1800		
Samt.		17530				

OFNASKRÁ 2.HÆÐ

Hitaveita Framrás 75°C  
Bakrás 35°C  
Innihiti 20°C  
dt=35°C

Herbergi	Ofn nr	Afköst W	Hæð	Lengd	Valdir ofnar	Ofnlokar
Gangur	201	900	600	1800		
Skrifstofa	202	900	400	2600		
"	203	900	400	1800		
"	204	900	400	1800		
"	205	800	400	2600		
"	206	650	400	2000		
"	207	650	400	2000		
"	208	650	400	1800		
"	209	650	400	1800		
"	210	650	400	1800		
Matsalur	211	1296	112	3250	ofn í gólfi	
"	212	1296	112	3250	ofn í gólfi	
"	213	1296	112	3250	ofn í gólfi	
Setustofa	214	1265	210	2000		
"	215	1265	210	2000		
Líkamsrækt	216	800	400	1800		
"	217	800	400	1800		
"	218	800	400	1800		
Búningsherbergi	219	700	600	800		
Matsalur	220	900	600	1800		
Samt.		18068				

OFNASKRÁ VERKSTJÓRAHERBERGJUM

Hitaveita Framrás 75°C  
Bakrás 35°C  
Innihiti 20°C  
dt=35°C

Herbergi	Ofn nr	Afköst W	Hæð	Lengd	Valdir ofnar	Ofnlokar
Verkstjóri	301	930	500	1000		
Snyrting	302	400	500	600		
Verkstjóri	303	670	500	900		
"	304	1130	500	1500		
"	305	1600	500	1500		
"	306	1300	500	1500		
Rafmagnsvörur	307	400	500	800		
Snyrting	308	400	600	1000		
Samt.		6830				